

HARRIMAN

ADDENDUM

Date April 28, 2017

To Prospective Bidders

Re Addendum No. 2 to the Construction Documents for:

Central Maine Community College
ECE Area Renovation
Auburn, Maine
Project No. 16611

This Addendum forms a part of the Contract Documents and modifies the original Construction Documents dated March 29, 2017 and Addendum No. 1 dated April 20, 2017. Acknowledge receipt of this Addendum in the space provided in the Bid Form.

This Addendum consists of two pages and SKA06.

Harriman

Mark D. Lee, AIA, LEED AP
Principal

46 HARRIMAN DRIVE
AUBURN, ME 04210
207.784.5100

123 MIDDLE STREET
PORTLAND, ME 04101
207.775.0053

33 JEWELL COURT, SUITE 101
PORTSMOUTH, NH 03801
603.626.1242

170 MILK STREET, SUITE 5
BOSTON, MA 02109-3438
617.426.5050

www.harriman.com

CHANGES TO SPECIFICATIONS

1. SECTION 098413 - FIXED SOUND-ABSORPTIVE PANELS


a. Article 2.2, D, delete and replace with the following:

“D. Facing Material, F1: Fabric from same dye lot; color and pattern as follows:

1. Manufacturer: Architex.
2. Pattern Name: Jump for Joy, We Are the World Collection.
 - a. Color: Hopscotch.
3. Fiber Content: 100% Polyester.
4. Width: 54 inches usable.
5. Pattern Repeat: 28.25 inches vertically, 15.0 inches horizontally.
6. Flammability: California Technical Bulletin 117.
7. Finish: Crypton.”

DRAWINGS ISSUED WITH THIS ADDENDUM

1. SKA06 - UPDATED EXISTING CONDITIONS AND PROPOSED GRADING



Auburn, ME
207.784.5100
Portland, ME
207.775.0053
Portsmouth, NH
603.626.1242
Boston, MA
617.426.5050


CENTRAL MAINE COMMUNITY COLLEGE ECE AREA RENOVATION

AUBURN, MAINE

HA Project No. 16611



GRAPHIC SCALE



Date 04-28-17

Scale 1"=20'

© 2017 Harriman Associates

UPDATED EXISTING
CONDITIONS AND
PROPOSED GRADING

SKA06

